



**Safety & Buildings Division**  
201 West Washington Avenue  
P.O. Box 2658  
Madison, WI 53701-2658

Evaluation #

200261-H

## Wisconsin Building Product Evaluation

### Water Heaters:

**Manufacturer:** American Water Heater Company  
1100 E. Fairview Ave.  
P.O. Box 1378  
Johnson City, TN 37605-1378

**Approved Product(s):** Trade Name: **MOR-FLO, Champion, American, U.S., and Craftmaster**

DVG(1, 5, 6, 8, 9,10,12)(1, 2)-40S38-(N, P)  
DVG(1, 2)(A, E, F, H, J)4038S-(N, P)  
DVG(1, 5, 6, 8, 9,10, 12)(1, 2)-50T42-(N, P)  
DVG(1, 2)(A, E, F, H, J)5042T-(N, P)

Trade Name: **Polaris**  
PBG(6, 9, 10, 12)2-(34S100, 50T100)- 2(N,P)  
PBCG (3, 5, 6, 9, 12) 2-(34S100, 50T100)-2 (N,P)

PG(3,5,6,8,9,10,12) 34-100-2(N,P)V  
PGC(3,5,6,8,9,10,12) 34-100-2(N,P)V  
PG(3,5,6,8,9,10,12) 34-130-2(N,P)V  
PGC(3,5,6,8,9,10,12) 34-130-2(N,P)V  
PG(3,5,6,8,9,10,12) 50-130-2(N,P)V  
PGC(3,5,6,8,9,10,12) 50-130-2(N,P)V  
PG(3,5,6,8,9,10,12) 50-175-3(N,P)V  
PGC(3,5,6,8,9,10,12) 50-175-3(N,P)V  
PG(3,5,6,8,9,10,12) 50-199-3(N,P)V  
PGC(3,5,6,8,9,10,12) 50-199-3(N,P)V

**SCOPE OF EVALUATION:** This review includes the cited: Comm code requirements in accordance with the current **Wisconsin Dwelling Code (UDC)**; **International Building Code (IBC)**; **International Mechanical Code (IMC)**; and **International Fuel Gas Code (IFGC)**.

**TESTS:** The water heaters were evaluated in accordance with ANSI Z21.10.3 Standard and were found to be acceptable to be covered under the CSA International Certification Service.

**LIMITATIONS OF APPROVAL:** The water heaters shall be installed as allowed in **s. Comm 23.04(3)** and **Table 23.04-A** of the **UDC**; **s. IMC 301.1** and **916.1**; **s. IFGC 630.1 [Comm 65.0630]**, their listing and the manufacturer's recommendations.

This approval will be valid through December 31, 2007, unless manufacturing modifications are made to the product or a re-examination is deemed necessary by the department.

The Wisconsin Building Products Evaluation number must be provided when plans that include this product are submitted for review.

**DISCLAIMER:** The department is in no way endorsing or advertising this product. This approval addresses only the specified applications for the product and does not waive any code requirement not specified in this document.

Revision Date:

Approval Date: February 17, 2003 By: \_\_\_\_\_

Lee E. Finley, Jr.  
Product/Material &  
Building Plan Review  
Integrated Services Bureau

200261-H.doc